



City of Frostburg 2020 Drinking Water Quality Report

Important Information Concerning Your Drinking Water:

We're pleased to present to you the Annual Water Quality Report for 2020. This report is designed to inform you about the water quality and services we deliver to you every day. Maryland Environmental Service, an Agency of the State of Maryland, began operating the water treatment facility in January 2002 and prepared this report on behalf of the City of Frostburg.

The Environmental Protection Agency (EPA) regulates Public Water Systems and the contaminants found in water through the implementation of the Safe Drinking Water Act (SDWA). The SDWA sets regulations and guidelines for how public water systems operate, identifies several hundred drinking water contaminants and establishes monitoring frequencies and limitations. The Maryland Department of the Environment (MDE) is responsible for the enforcement of the SDWA and routinely conducts sanitary surveys, inspections and monitoring for all public water systems. MES provides safe, dependable operations of the water system and is dedicated to consistently providing high quality drinking water that meets or exceeds the SDWA standards.

If you have any questions about this report or have questions concerning your water utility, please contact **Jay Janney at 410-729-8350, e-mail jjanney@menv.com** .



Public Meeting Information:

For the opportunity to ask questions or participate in decisions that may affect your drinking water quality, please visit the City's webpage at www.frostburgcity.org to find upcoming meetings of the Mayor and Council. Customers may also call 301-689-6000 for more information.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Inside This Issue:

Definitions	2
Special Points of Interest	2
Water Quality Report	3
Lead in Drinking Water	4
Sources of Drinking Water	4
TOC Removal	4

The Maryland Environmental Service (MES) operates and maintains the water treatment facility for the City of Frostburg. The facility is rated to treat 3.0 million gallons per day (MGD) and currently averages 1.2 MGD. The Frostburg water treatment facility receives raw water from numerous sources. MES maintains 29 springhouses with related collection and transmission equipment, and two deep wells in the Pocono aquifer. The balance of raw water is pumped from the Piney Dam reservoir in Garrett County. All raw water sources are commingled in a one million gallon supply reservoir which feeds the water treatment facility. The raw water is treated using a surface water treatment plant which consists of four basic components: coagulation, flocculation, sedimentation and filtration. These processes are specifically designed to treat the water at Frostburg. The treated water is stored in two finished water reservoirs. The last steps of treatment include the addition of Chlorine for disinfection, fluoride for dental protection and a corrosion inhibitor to help maintain the distribution system.

The Maryland Environmental Service provides personnel who are properly trained and licensed to operate and maintain the water treatment facility and related equipment in accordance with all applicable regulations. The operational tasks include daily visits to the water treatment facility, checking the facility, performing daily process testing, performing daily, weekly, and monthly calibrations/maintenance, performing all outside grounds maintenance, and continuing on-going quality control and preventative maintenance programs. The Maryland Environmental Service procures all necessary supplies and materials outlined in the operating budget for the efficient control of treatment, compiles and submits all reports required by Local, State, and Federal Regulatory Agencies and provides response 24 hours per day in the event of emergency situations such as an equipment malfunction.

Special points of interest:

- The water at Frostburg is tested for over 100 different compounds.
- The City of Frostburg's Drinking Water met all of the State and Federal requirements.

Definitions:

- Maximum Contaminant Level Goal (MCLG) - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
- Maximum Contaminant Level (MCL) - The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.
- Action Level - The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.
- Treatment Technique (TT) - A required process intended to reduce the level of a contaminant in drinking water.
- Turbidity - Relates to a condition where suspended particles are present in the water. Turbidity measurements are a way to describe the level of "cloudiness" of the water.
- NTU - Nephelometric Turbidity Units. Units of measurement used to report the level of turbidity or "cloudiness" in the water.
- ppb - Parts per billion or micrograms per liter.
- ppm - parts per million or milligrams per liter



City of Frostburg Treated Water Quality Report 2020

	Highest Level Allowed	Highest Level	Ideal Goal
Contaminant	EPAs MCL	Detected	(EPA's MCLG)
Regulated at the Treatment Plant			
Nitrate	10 ppm	1.1 ppm	10 ppm
Typical Sources of Contaminant: Runoff from the use of fertilizer		Range (0.65 to 1.71 ppm)	
Fluoride	4.0 ppm	0.29 ppm	4.0 ppm
Typical Sources of Contaminant: Added for dental protection		Range (0.0 to 0.29 ppm)	
Barium	2 ppm	0.05 ppm	2 ppm
Typical Sources of Contaminant: Erosion of natural deposits		Range (0.0 to 0.05 ppm)	
Chlorine	4 ppm	1.07*	4 ppm
Typical Sources of Contaminant: Added for microbial protection		Range (1.01 to 1.12) * Average	
Ethylene dibromide (2018 Testing)	50 ppt	10 ppt	0 ppt
Typical Sources of Contaminant: Discharge from petroleum refineries			
Regulated in the Distribution System			
	EPAs MCL	Detected	(EPA's MCLG)
Total Trihalomethanes (TTHM)	80 ppb	(Range 20.7 - 72.5)* 49 ppb**	N/A
Haloacetic Acids (HAA5)	60 ppb	(Range 4.8 - 21.0)* 14 ppb**	N/A
Typical Source of Contaminants: By-product of drinking water disinfection			
* Highest Individual Result from a Single Location			
** Four monitoring sites are individually averaged and reported quarterly. Compliance is determined on a Locational Rolling Annual Average (LRAA) of the individual sites. Value reported is the highest LRAA during 2020.			
Treatment Technique			
Turbidity	TT = filtration 0.3 NTU (Range 0.02- 0.15) Average 0.07 NTU		
Typical Source of Contaminant: Soil Runoff			
Turbidity cannot exceed 1.0 NTU and must be less than or equal to 0.3 NTU taken each month-in at least 95% of the measurements.			
The water plant consistently met all of the turbidity requirements in 2020.			
Regulated at the Consumer's Tap			
	Action Level	Detected	(EPA's MCLG)
Copper - (2018 Testing)	1.3 ppm	0.09 ppm*	1.3 ppm
Lead - (2018 Testing)	15 ppb	0.0 ppb*	0.0 ppb
Typical Source of Contaminant: Corrosion of household plumbing		* 90th Percentile	

The table above lists all the drinking water contaminants that were detected during the 2020 calendar year. The presence of these compounds in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in the table is from testing done January 1 – December 31, 2020. The State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

Total Organic Carbon (TOC)

The percentage of Total Organic Carbon (TOC) removal was measured each quarter and the system met all TOC removal requirements. During 2020 the minimum required TOC removal rate was between 45% to 72%. The average removal rate during 2020 was 54%.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some compounds. The presence of these compounds does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA's) Safe Drinking Water Act Hotline (1-800-426-4791)

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain compounds in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Source Water Assessment

The Maryland Department of the Environment completed a source water assessment. You may read this source water assessment by contacting the City office.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Frostburg is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

Contaminants That May Be Present in Source Water:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. Inorganic Contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming. Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. Radioactive Contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

Thank you for another great year of Water Quality!

